

STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 1
PROJECT NO. ENH-89(26)
CONTROL NO. 22355
CALL NO. 215
BLAIR DEPOT IN THE PARK
LETTING DATE: JULY 26, 2012

Plan sheet 21 (sheet A5.0) is amended as follows:

1. In the DOOR SCHEDULE table, for both "Mark CS1 and CS2", the following changes are made:
 - a. The HARDWARE SET # of EX03 is eliminated.
 - b. The REMARKS column is amended to read:

PLATFORM ACCESS DOOR. SEE DOOR GENERAL NOTE #3.
2. The DOOR GENERAL NOTES box is amended to include the following:
3. 2x4 Wood Frame of Door to be Screwed into Jamb, Head & Sill Framing of Platform. Center 3" Screw, One at Each jamb, Head & Sill. See Specifications for Screw Type.

* * * * *

Upon execution of the contract, the plans will be revised to reflect these changes.

DEPARTMENT OF ROADS

Original Signed By Kendall Stege

for Claude Oie
Construction Engineer

Issued: July 19, 2012

CO:215AD107

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.