

STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 3
PROJECT NO. STPD-133-3(102)
CONTROL NO. 21791
CALL NO. 245
N-133, N-36 NORTH, OMAHA
LETTING DATE: OCTOBER 4, 2012

Plan sheet 2-T5 is amended to include the following:

NOTE: Concrete Pavement Thickness = 8".
Asphalt Surface Thickness = 4"
(Exception: 1 – segment of 20 Sta. Lt & Rt &
1 – segment of 9 Sta. Lt & Rt = 8".)

* * * * *

On plan sheet 33, the entire note concerning "NDOR or Contractor supplied material for the lighting systems" (located directly under the words PHOTO CONTROL in the pole diagram) is void.

The Contractor shall be responsible to furnish all material required for the temporary lighting systems, as per the provision titled **CROSSOVER LIGHTING SYSTEM** on pages 122 and 123 of the Special Provisions.

* * * * *

Upon execution of the contract, the plans will be revised to reflect this change.

DEPARTMENT OF ROADS

Original Signed by Claude Oie

Claude Oie
Construction Engineer

Issued: September 21, 2012

CO: 245AD310

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.