

## **SECTION 1041 -- DRAIN TILE**

### **1041.01 -- Description**

Concrete drain tile shall conform to the "Extra-Quality Drain Tile" requirements of AASHTO M 178.

### **1041.02 -- Acceptance Requirements**

Drain tile will be accepted based on requirements of this Section and sampling and testing requirements in accordance with the NDR *Materials Sampling Guide*.

## **SECTION 1042 -- STRUCTURAL PLATE PIPE**

### **1042.01 -- Description**

1. Galvanized steel structural plate for pipe, pipe-arches, and arches shall conform to the requirements of AASHTO M 167, with the exception that units on which the spelter coating has been damaged shall be repaired in accordance with Section 1061.

2. Aluminum alloy structural plate for pipe, pipe-arches, and arches shall conform to the requirements of AASHTO M 219.

### **1042.02 -- Acceptance Requirements**

Structural pipe plate will be accepted based on requirements of this Section and sampling and testing requirements in accordance with the NDR *Materials Sampling Guide*.