

SECTION 727 -- SUBSURFACE DRAINAGE MATTING

727.01 -- Description

This work shall consist of furnishing and installing drainage matting at bridge ends as shown in the plans.

727.02 -- Material Requirements

1. The drainage matting to be used shall be on the NDR Approved Products List.
2. The matting shall have a minimum nominal thickness of 0.22 inch.

727.03 -- Construction Methods

1. The Contractor shall place the matting at the location shown in the plans.
2. The matting shall be placed in accordance with the manufacturer's recommendation.
3. A 3 inch minimum lap shall be used when splicing the matting.

727.04 -- Method of Measurement

Subsurface drainage matting is measured by the square yard of area covered with no allowance for overlaps.

727.05 -- Basis of Payment

- | 1. Pay Item | Pay Unit |
|-----------------------------|------------------|
| Subsurface Drainage Matting | Square Yard (SY) |
2. Payment is full compensation for all work prescribed in this Section.